

7 April 2015
EA Project No. 1470405

TO: Bidders of Record

FROM: EA Engineering, Science, and Technology Inc., P.B.C.
11202 Racetrack Road
Unit 103
Ocean Pines, MD 21811

RE: Addendum No. 3
Town of Berlin Branch Street Well House Emergency Generator
Berlin, MD

TO ALL BIDDERS: This Addendum No. 3 contains direction for modification to Contract Documents. This Addendum No. 3 shall supplement, amend, and become part of the Contract Documents and Construction Specifications for the title project and contract. All bids shall be based on this addendum in accordance with the Bidding Documents.

This Addendum contains the following:

- Contract Document Clarifications

CONTRACT DOCUMENT CLARIFICATIONS

1. **NEW Bid Due Date:** Monday April 13, 2015 at 2:00pm.
2. In Section 26 32 13, Emergency Generator (and as modified by Addendum No. 1), revise the section as follows:
 - a. In article 2.12.K. DELETE "... ASCO Series 300SE..." and SUBSTITUTE "...ASCO Series 7000SE..."
 - b. In article 2.12.L, DELETE "...4 pole, .." and SUBSTITUTE "...3 pole, ..."
 - c. DELETE article 2.13.C.3 in its entirety. (DELETE requirement for a programmed transition feature.)
 - d. DELETE article 2.13.C.5 in its entirety. (DELETE requirement for space heater.)
3. On Figure 1, sheet 1 of 2 (issued by Addendum 2), DELETE the "SPARE THREE INCH CONDUIT" routed from the generator to the ATS and SUBSTITUTE "TWO ONE INCH CONDUITS FOR CONTROL POWER AND CONTROL SIGNALS".